

Adopted:	13 March 2019
Review:	Every three years or as required
Consultation:	Internal Consultation with Staff
Related Documents:	Collective management of water allocations

1. Scope

This policy applies to the management of flow and design allocations of water through all ALIL shareholders offtakes.

2. Purpose

The purpose of this policy is to provide guidance on how ALIL manages the water entitlement/ flow allocation and the design allocation.

The ALIL scheme provides for a flow allocation or water entitlement that relates to the ALIL share allocation on a property. Every 1 share held in the company entitles the holder to delivery of 0.01 litres per second of water to the property.

In addition, the scheme was designed to provide for an additional 18.3% capacity on existing shareholdings that were in place when the 2013 prospectus was offered, providing that design flow was not greater than the maximum supply rate of 0.58 litres per second of water.

It is recognised that some irrigators have peaks and troughs in demand throughout the day, so the instantaneous rate taken through a property offtake will not always match the water entitlement/allocation flow.

ALIL has flow meters on all offtakes in order to monitor and manage the level of water use.

3. Definitions

Water Entitlement (Allocation of Water): The flow in litres per second available from an offtake based on the shares contracted for that offtake/property. This will never exceed the maximum supply rate.

Design Capacity: The flow in litres per second based on the existing shareholding's water entitlement at the time of the 2013 prospectus plus 18.3%. The design capacity equals the maximum supply rate for the property serviced by the offtake at the time of the design.

Maximum Supply Rate: means the delivery of 5mm per day per hectare or 0.58 litres per second of water for each hectare of land to be irrigated by the Farmer (with variation to that rate where water is being taken for storage) or such other rate as may be determined by the Board.

4. Policy Details

The instantaneous take of water through a property offtake shall not exceed the design capacity for that offtake.

The volume of water taken through a property offtake must meet the water entitlement for that property offtake over a 24-hour period.

The design capacity and water entitlement for the property offtake are detailed in the Water Supply Agreement (WSA) for the property.

5. Sign-Off and Revisions:

Revision Chronology					
Rev	Revision Status	Date	Preparer	Checked	Approved
1	<i>First draft</i>	1/3/2019	RAW	CF	
2	<i>Approved by Board</i>	13/3/19		CF	Board